



RIASSUNTO RAPPORTI ANALISI 2017

DATA PRELIEVI	08.08.2017		08.08.2017		12.06.2017		12.06.2017	
Luogo	Fontana Molina Buseno	Valore tolleranza	Serbatoio Toga Buseno	Valore tolleranza	Fontanon San Vittore	Valore tolleranza	Salzin San Vittore	Valore tolleranza
ANALISI MICROBIOLOGICA								
Germi aerobi, mesofili	0 UFC / ml	300 UFC / mL	0 UFC / ml	20 UFC / ml	< 10 UFC / ml	20 UFC / ml	< 10 UFC / ml	20 UFC / ml
Escherichia coli	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml
Enterococchi	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml
ANALISI FISICO CHIMICA								
pH	6.89		6.77					
Conduttività	50 mcS/cm		59 mcS / cm					
Temperatura	20.5 °C		7.3 °C		5.4 °C		5.5 °C	
Valutazione	ineccepibile		ineccepibile		ineccepibile		ineccepibile	

6542 Buseno, 22 agosto 2017